

- Service flow 54 gpm, backwash flow 22 gpm with built in meter on side port of valve body and fitting kit installed
- Solid state microprocessor with easy access front panel settings
- Four methods to initiate regeneration; meter immediate, meter delayed, time clock delayed or pressure differential
- Fully programmable regeneration cycle times
- Programmable regeneration cycle times
- Days override feature; 1 28 days available
- Backwash and brining ability for Softeners to 24" diameter tanks, backwash filters to 18"
- Downflow/upflow regeneration
- Stores system configuration and operation data in nonvolatile memory
- Coin Cell Lithium battery back-up with an 8 hour carry over
- Level VI 15-volt output DC power supply provides safe and easy installation
- Control valve design provides optimum service and backwash rates
- Soft/treated water regeneration
- Pre or post soft/treated water regenerant refill
- 12-hour clock
- Reliable and proven DC drives
- One piece expanding seal spacer stack assembly
- Linearly reciprocating piston operation

Water Specialist 1.5" EE Twin Alternating Specifications

Inlet/Outlet Fittings	1 5" NPT
Cycles	
Valve Material	
	<u>.</u>
Regeneration	Downlow/Opilow
FLOW RATES	
Service @ 15 psi drop (includes fitting kit and meter)	54 apm
Backwash @ 25 psi drop (includes fitting kit)	
Cv Service	.
Cv Backwash	
OPERATING PRESSURES	
	00 noi 105 noi /1 / 9 6 hor
Minimum/Maximum	20 psi - 125 psi (1.4 - 8.6 bar)
OPERATING TEMPERATURES	
Minimum/Maximum	40° - 110° F (4 - 43° C)
	,
METER	
Accuracy	± 5%
Flow Rate Range	0.5 - 75 gpm
Volume Range	20 - 1,500,000 gallons
Totalizer	
DIMENSIONS & WEIGHT	
Distributor Pilot	1.90" OD (1.5" NPS)
Drain Line	1" Male NPT Elbow
Brine Line	½" OD Poly Tube Compression
Mounting Base	4" - 8 UN Thread
Height From Top of Tank	
Weight	18 lbs.
ELECTRICAL SPECIFICATIONS	POWER SUPPLY
	U.S.
Supply Voltage	
Supply Frequency	
Output Voltage	
Output Current	500 mA
TANK APPLICATIONS	
Water Softener	12" - 24" diameter
Water Filter (1)	
Tracor rincor (1)	illimit 12 10 diditiotor
CYCLES OF OPERATION (Softener / Filter)	
-	Softener Filter
Cycle	Range of time in minutes
1. Backwash 1st	Off-120 Backwash Off-120
2. Regenerate Draw/Slow Rinse	
3. Backwash 2 nd	
4. Fast Rinse	
5. Regenerant Refill	
6. Service (downflow)	
or corrior (dominion)	

Options: Backwash Filter, Weather Cover

Compatible with the following typical concentration of regenerants or chemicals: Sodium chloride, potassium chloride, chlorine and chloramines

1. Filter tank size calculated @ 10 gpm of backwash per square foot of bed area